

Technical bid evaluation summary after verification of documents by bidders in accordance to query on shortfall document (Revised - Remarks Sl.7)					
Sl	Name of Bidder	Shorfall query asked on CPP	Remarks	Shorfall query asked via email	Remarks
1	Novateur Electrical and Digital Systems Private Limited	Supporting document for Surge IEC 610004-5 Level 4 certificate to produce.	As stated by the bidder, they couldnot replied in time in CPP portal due Pandemic situation. Document submitted by email was accepted. Verified and found in order	----	Declared Qualified
2	Prostarm Info Systems Ltd(Prostar Micronova Power Systems Pvt Ltd)	Supporting document for Battery Test certificate, Surge IEC 610004-5 Level 4,RoHS Compliance, UL or IEC 62310-3 2008 to produce. Proof of Service Setup in North East to produce.	After verification of documents submitted in CPP Portal, further query was asked via email	1. Static Switch Model & Datasheet(for both 3KVA & 5 KVA) and UL/IEC certificate iro static switch (for both 3KVA & 5 KVA) . 2. It is requested to mention offered make and model of both 5KVA and 3KVA ups and static switch. 3. Two Service Centre/ASP) in North East Region may specify.	UL / IEC certificate not submitted. Declared disqualified
3	Elnova Private Limited	Work completion certificate for GeM contract reference GEMC-511687764073752 dated 23.09.2019 is to produce. Battery Test certificate, Surge IEC 610004-5 Level 4,UL or IEC 62310-3 2008,NABL test report to produce.	After verification of documents submitted in CPP Portal, further query was asked via email	1.Work Completion Certificate not meeting tender requirement. 2. THE OFFERED UPS OEM SHOULD NOT HAVE HISTORY OF BLACKLISTED / DEBARRED OF BUSINESS FROM GOVT. OR PSU IN INDIA :affidavit in this regard to be produced. 3. Static Switch : Datasheet and UL/IEC certificate not provided for both 5 KVA & 3 KVA.	The bidder submitted experience of his Sl. No required experience certificate could produced on the name of bidder. Declared disqualified.
4	ECS ENGINEERING PVT LTD	Work completion certificate for the work at AAI Dimapur to be submitted. Supporting document for Battery Test certificate, Surge IEC 610004-5 Level 4,UL or IEC 62310-3 2008,NABL test report to produce.	After verification of documents submitted in CPP Portal, further query was asked via email After verification of documents submitted in CPP Portal, further query was asked via email	1. Static Switch Datasheet(for both 3KVA & 5 KVA) and UL/IEC certificate iro static switch (for both 3KVA & 5 KVA) . 2. BIS Certificate for Both 5KVA and 3 KVA . 3. It is requested to mention offered make and model of both 5KVA and 3KVA ups and static switch. 4. Your offered model name is not mentioned in the data sheet. Request clarification.	Bidder offering other product since couldnot justify tender requirement in their offered product. Declared disqualified.

638486/2020/O/o GM(CNS)-NER

Sl	Name of Bidder	Shorfall query asked on CPP	Remarks	Shorfall query asked via email	Remarks
5	BMG Informatics Pvt Ltd	Supporting document for NABL Test certificate for 5KVA to produce.	Documents found in roder, declared qualified	-----	Declared Qualified
6	Trans Virtual Pvt Ltd	Supporting document for Surge IEC 610004-5 Level 4 and proof of Service Setup in North East to submit.	After verification of documents submitted in CPP Portal, further query was asked via email	1. BIS Certificate for Both 5KVA and 3 KVA . 2. NABL test certificate for 3 KVA & 5 KVA ratings is not matching with offered model in tender. Please clarify 3. It is requested to mention offered make and model of both 5KVA and 3KVA ups and static switch. 4. Your offered model name is not mentioned in the data sheet. Request clarification.	Bidder offering other product since couldnot justify tender requirement in their offered product. Declared disqualified.
7	RS Power Systems Pvt. Ltd	Supporting document for UL or IEC 62310-3 2008 for static switch and Black listed undertaking to produce.	After verification of documents submitted in CPP Portal, further query was asked via email	1. Make& Model for 3KVA & 5 KVA Product BROCHURE submitted has no model number mentioned in it, hence specifications cannot be substantiated with technical compliance ,Clarification in this regard may please be provided. 2. BIS MODEL for 5 KVA is 5000-OL-3 whereas offered model in tender is 5000 OL as per Annexure 1 .Please clarify. 3. Required UPS Rating as per tender: 5 KVA/4.5 KW whereas Test Report submitted for UPS Rating: 5KVA/3.5KW Please clarify. 4. Required UPS Rating as per tender: 3 KVA/2.4 KW whereas Test Report submitted for UPS Rating: 3KVA/2.1 KW Please clarify.	In the test certificated produced by the bidder for their offered model, output power for 5 and 3 KVA UPS are shown 3.5 and 2.1 KW respectively, which is not meeting the tender requirement Declared Disqualified.
8	DS SYSTEMS PVT. LTD	Supporting document for IEC 61000-4-5 level4 to produce.	Documents found in roder, declared qualified	-----	Declared Qualified

18/10/2020 10:04 PM

SUNIT KUMAR ROY
(DGM(CNS)-NER)

Note No. #70

All the three technically qualified bidders were requested to extend the bid by 31/12/2020.

Out of three qualified bidders, following two bidders given willingness for extension of bid upto 31/12/2020(C/299-301).

1. M/s DS systems, Pvt. Ltd.
2. M/s Novateur electricals and Digital systems Private Limited .

M/s BMG Informatics limited express their inability to extend their bid(C/302-303). In view of the above it is requested to open financial bid of following two bidders

- M/s DS systems, Pvt. Ltd.
- M/s Novateur electricals and Digital systems Private Limited .

Other bidder(M/s BMG Informatics limited) will be treated as disqualified . Financial bid will be opened 7 days after notifying technical evaluation report in CPP.

Submitted for approval.

22/10/2020 1:11 PM

DIPAYAN ROY
(SM(ELEX)-NER)

Note No. #71

Following two bidders out of three, technical bid of whom are approved for acceptance, have submitted their willingness to extend their bid via email.

- M/s DS systems, Pvt. Ltd. ([PUC/300](#))
- M/s Novateur electricals and Digital systems Private Limited . ([PUC/301](#))

One bidder M/s BMG Informatics limited conveyed their inability in extending the bid validity vide email placed at [PUC/302](#).

In view of above, it is recommended to notify the technical bid of M/s BMG Informatics limited as disqualified and acceptance of technical bids of M/s DS systems, Pvt. Ltd. and M/s Novateur electricals and Digital systems Private Limited in CPP portal.

Date of opening of finance bid shall be notified after 7 days of uploading technical evaluation report in CPP Portal.

Submitted for approval please.

Please refer [Note#74](#) of SM(CNS) NER above, in accordance to the [para 20 of Ministry of Commerce and Industry circular on public procurement\(c\)Order 2017-revision \(PUC/325\)](#) the guidelines contained therein shall not be applicable for the NIT under reference.

However, as stated in the above noting, it is recommended to ask the eligible bidders to submit their declaration in accordance to [Para 12 of Ministry of Finance order dated 23/07/2020\(C/308\)](#).

Submitted please.

06/11/2020 3:52 PM

SUNIT KUMAR ROY
(DGM(CNS)-NER)

Note No. #76

Agreed. Please do the needful.

10/11/2020 10:43 AM

RAVI KANT
(GM(CNS)-NER)

Note No. #77

Forwarded for further n/a.

10/11/2020 12:08 PM

SUNIT KUMAR ROY
(DGM(CNS)-NER)

Note No. #78

Certificate regarding compliance in r/o restrictions of Ministry of Finance order dated 23/07/2020 on Public Procurement received from both the technically qualified bidders (C/326-327)

- M/s DS systems, Pvt. Ltd.
- M/s Novateur electricals and Digital systems Private Limited .

Request permission to open the technical bid of the above two bidders.
Financial bid will be opened 7 days after notifying technical evaluation report in CPP.
submitted for approval.

19/11/2020 3:41 PM

DIPAYAN ROY
(SM(ELEX)-NER)

Note No. #79

May please refer above note (Note#77), it is recommended for approval to open the Technical bid of both eligible bidders.

19/11/2020 5:30 PM

SUNIT KUMAR ROY

(DGM(CNS)-NER)

Note No. #80

Technical bid is already opened.

20/11/2020 11:52 AM

RAVI KANT
(GM(CNS)-NER)

Note No. #81

Note # 79 of undersigned may please be ignored.

Certificate regarding compliance in r/o restrictions of Ministry of Finance order dated 23/07/2020 on Public Procurement received from both the technically qualified bidders (C/326-327) are in order. Kindly refer above note [\(Note#77\)](#), it is recommended for approval to open the finance bid of both eligible bidders.

20/11/2020 12:34 PM

SUNIT KUMAR ROY
(DGM(CNS)-NER)

Note No. #82

Approved as recommended.

20/11/2020 1:36 PM

RAVI KANT
(GM(CNS)-NER)

Note No. #83

For further n/a.

20/11/2020 3:16 PM

SUNIT KUMAR ROY
(DGM(CNS)-NER)

Signature Not Verified

Digitally signed by DIPAYAN ROY
Date: 2020.11.24 17:17:11 IST
Location: eProcurement System for Central
PSUs

