


MEMO FORWARDING e-TENDERS TO HIGHER AUTHORITIES

1	Name of work	:	Provision of interleaving circuits for PAPIs and separate circuit for runway guard lights at Mangaluru International Airport. SH: - Supply of airfield ground lighting cable.
2	Ref. to Admn. Approval & Expenditure sanction	:	AAI/ML/ENGG(E)/2019-20/13 Date: 31.01.2020 Rs.75,84,534/-
	(i) No. & Date	:	
	(ii) Amount	:	
	(iii) Proportionate amount available for the work included in the present Tenders	:	Budget BE 20-21 AS scheme S.No.12 of Rs 5 Lakh
3	Ref. To Tech Sanction		AAI/ ML/ENGG(E)/TS/14 dt: 31.03.2020 Rs. 18,92,000/-
	(i) No. & Date	:	
	(ii) Amount	:	
4	Scope of work for which Tenders have been called for clearly indicating the items omitted from the sanction estimate	:	Supply of Airfield Lighting Cable and associated works as per BOQ.
5	Ref. To Approval of NIT		
	(i) Authority	:	Asst. Gen. Manager, Engg (E) Mangaluru International Airport.
	(ii) Date	:	AAI/ML/ENGG (E)/AGM (E)/ NIT-01/2020-21/880 dt: 05.05.2020
	(iii) Est. Amount put to Tender	:	Rs. 18,92,000/-
6	Ref. To Publicity		
	(i) Date on which notice inviting Tender was placed on notice Board	:	05.05.2020
	(ii) Date of which it was circulated to other offices	:	05.05.2020 (Through CPP Portal, AAI website)
	(iii) Name of News papers (with dates) in which the notice inviting Tender was actually advertised	:	NA

7	(i) The date and time at which Tender were due to be received	:	18.05.2020 upto 18:00 hrs.	
	(ii) Postponed date and time if any	:	10.06.2020 upto 18:00 hrs	
	(iii) Reasons for postponement	:	To give more time to bidders due to COVID-19. Thus for more competition	
	(iv) Reference to publicity in regard to postponement of tenders	:	E-tender portal	
8	The date from which Tenders were available for sale contractors	:	10.06.2020	
9	Particulars of contractors to whom Tender were sold quoting authority for issue of tenders	:	Nil	
10. Sl. No	Name of contractor	Whether Proprietorship/ Partnership	Date of issue of Tenders	Remarks
(1)	(2)	(3)	(4)	(5)
1	M/s Ankur Technocrats, Delhi	Proprietorship	15.05.2020	
2	M/s Techno Electricals, Baroda	Partnership	18.05.2020	
3	M/s AMA Pvt Ltd,Mumbai	Partnership	29.05.2020	
4	M/s Manish Electricals, Gwalior	Proprietorship	18.05.2020	
10	Opening of Tenders	:		
	(i) Date and time at which Tenders were due to be open(Financial Bid)	:	Price bid –24.06.2020 at 12.00 hrs	
	a) Date and time at which Tenders were actually opened(Financial Bid)	:	Price bid –24.06.2020 at 12:30hrs	
	b) Name and Designation of officers who actually opened the Tenders (price bid)	:	1. Sh. S Ram Mohan, Asst.Gen. Manager (E.E) 2. Sh. Praveen, Manager (F)	
	c) Name of contractors present at the time of opening of Tenders	:	NIL	
	(ii) Name and designation of any other person present	:	NIL	

Contd..3

POSITION OF TENDERS RECEIVED

Sl.No (i)	Name of contractor (ii)	Amount Excluding. GST (iii)	% age above or below the justified cost (excl. GST) (iv)
1	M/s Ankur Technocrats, Delhi	Rs. 19,80,000/-	4.65 % Above
2	M/s AMA Pvt Ltd, Mumbai	Rs. 24,20,000/-	27.91 % Above
3	M/s Manish Electricals, Gwalior	Rs. 14,30,000/-	24.42 % Below
12.	(i) Justified percentage as worked by AAI	:	Rs. 18,92,000/- (excluding GST)
13.	Date on which validity of Tenders expires	:	90 DAYS from date of opening. (i.e.- on 21.09.2020)
14.	Remarks & Recommendations of the Executive Engineer	:	
	(i) Available of site	:	Yes
	(ii) Available of stipulated materials	:	N/A
	(iii) Approval of layout plans	:	-
	(iv) Approval to building, plans clearance from local body	:	N/A
	(v) Comments on the capabilities of three lowest Tenders including their financial and technical resources	:	Capable
	(vi) Is this the first call of Tenders? If not details of previous calls and results	:	N/A
15	Justification Based on market rate.		
16	Comments on the Tenders: Tender was floated for the above said work on 05.05.2020 Cover-I (Hard Copy & Prequalification Bid and Technical Bid) was opened on 15.06.2020 out of five agencies who participated four were qualified for the Cover-II opening. Cover-II (Financial Bid) was opened on 24.06.2020. The comparative statement was prepared with justification cost as the base (comparative statement including portal generated is enclosed). The offer of M/s Manish Electricals, Gwalior who quoted Rs. 14,30,000/- i.e. 24.42% below the justified cost of Rs. 18,92,000/- is the lowest. (without GST). The amount for this work can be realized from approved BE- 20-21 in which an amount of Rs 5.00 lakhs was earmarked for the work of "Provision of interleaving circuits for PAPIs and separate circuit for RWY guard lights" (Sl.No 12 of AS scheme). The rest of the amount can be sought in subsequent budgets. Hence financial concurrence for an amount of Rs. 14,30,000/- without GST (Rupees Fourteen Lakhs Thirty Thousand Only) plus applicable GST, may be accorded for awarding the work to the lowest bidder i.e to M/s Manish Electricals, Gwalior Vide D.O.P.8.5(a). Submitted for approval and forwarding please.  Asst.Gen.Manager (Engg.E) AAI, Mangaluru Intl. Airport		

Comparative statement

Name of work : Provision of interleaving circuits for PAPIs and separate circuit for runway guard lights at Mangaluru International Airport. SH: - Supply of airfield ground lighting cable.

Bid No. 2020_AAI_46263_1

Date of Financial Bid Opening :24.06.2020 at 12.00 hrs

Sl.No	Description	Unit	Qty	Justified		M/s Ankur Technocrats, Delhi		M/s AMA Pvt Ltd, Mumbai		M/s Manish Electricals,Gwalior	
				Rate	Amount	Rate	Amount	Rate	Amount	Rate	Amount
1	Supply of 1 x 6 sq.mm airfield cable of 5 KV grade consisting of stranded tinned copper conductor, inner semi-conductor layer, XLPE insulated, outer semi-conductor layer, copper or brass tape and finally XLPE/PVC/PE sheathed confirming to IS:7098 Part II amendments upto date. (Ref. technical specification)	Each	22000.00	86.00	1892000.00	90.00	1980000.00	110.00	2420000.00	65.00	1430000.00
A	Total				1892000.00		1980000.00		2420000.00		1430000.00
B	Grand Total				1892000.00		1980000.00		2420000.00		1430000.00
							4.65%		27.91%		-24.42%
							L2		L3		L1

Certified that I have personally conducted check of all quotations duly computed checked and satisfied myself that the checking work been properly done and the rates quoted by the contractor ie. totals are carried over correctly in the comparative statement.



Signature of the Asst.Gen.Manager (E-E)

Certified that I have personally conducted a test check of the computed & checked tenders forwarded by Deptt. Of Engg. And satisfied myself that the checking work has been properly done.

Signature of the AGM (Finance)

Government eProcurement System
Created By: RAM MOHAN S
Created Date/Time: 24-Jun-2020 12:15 PM
Tender Title: Provision of interleaving circuits for PAPIs and separate circuit for runway guard lights at Mangaluru International Airport SH
Supply of airfield lighting cable
Tender ID: 2020_AAI_46263_1

Tender Inviting Authority: Asst. Gen. Manager (Engg E), AAI Mangaluru, Airport.

Name of Work: Provision of interleaving circuits for PAPIs and separate circuit for runway guard lights at Mangaluru International Airport. S

Tender ID 2020_AAI_46263_1

SCHEDULE OF WORK / ITEM(S)

Sl.No	Description of Work / Item(s)	No.of Qty	Units	Estimated Rate	AMA Private Limited		ANKUR TECHNOCRATS		Manish Electricals		L1 Amount	L1 Vendor
					Rate	Amount	Rate	Amount	Rate	Amount		
1.00	Supply of 1 x 6 sq.mm airfield cable of 5 KV grade consisting of stranded tinned copper conductor, inner semi-conductor layer, XLPE insulated, outer semi-conductor layer, copper or brass tape and finally XLPE/PVC/PE sheathed confirming to IS:7098 Part II amendments upto date. (Ref. technical specification)	22000.00	Meters	0.00	110.00	2420000.00	90.00	1980000.00	65.00	1430000.00	1430000.00	Manish Electricals

Total in Figures

2420000.00

1980000.00

1430000.00

Lowest Amount Quoted BY: Manish Electricals(1430000.00)

BOQ Summary Details	
Tender Title: Provision of interleaving circuits for PAPIs and separate circuit for runway guard lights at Mangaluru International Airport SH Supply of airfield lighting cable	
Tender ID: 2020_AAI_46263_1	

Sheet Name	Sl.No	Bidder Name	Amount	Bid Rank
BoQ1	1	Manish Electricals ✓	1430000.00	L1 ✓
	2	ANKUR TECHNOCRATS ✓	1980000.00	L2 ✓
	3	AMA Private Limited ✓	2420000.00	L3 ✓

Justification Statement

Name of Work: Provision of interleaving circuits for PAPIs and separate circuit for RWY guard lights at Mangaluru International Airport.
SH:- Supply of airfield ground lighting cable.

SI No	Description	Quantity	Unit	Rate excluding GST	Amount
1	Supply of 1 x 6 sq.mm airfield cable of 5 KV grade consisting of stranded tinned copper conductor, inner semi-conductor layer, XLPE insulated, outer semi-conductor layer, copper or brass tape and finally XLPE/PVC/PE sheathed confirming to IS:7098 Part II amendments upto date. (Ref. technical specification)	22000.00	Metres	86.00	1892000.00 ✓
	Total				1892000.00 ✓
	GST @ 18%				
	Total				1892000.00 ✓
	Say				1892000.00 ✓

Rupees Eighteen Lakhs Ninety Two Thousand Only

GST will be paid as per actual at the time of payment on submission of GST invoice


16/6/2020
Asst. Gen. Manager (Engg-E)


16/06/2020
M (Fin)

S. Jayaram
16/06/2020
Asst. Gen. Manager (Engg-E)


16/6/20
Asst. Gen. Manager (Engg-E)
AAI, Mangaluru Intl. Airport