

**Note No. #1**

**Name of Work: - Provision of gas based fire suppression system for ATC tower & technical block at Diu Airport.**

**Budget: - Non-budgeted Scheme**

**Subject:- Budget allocation and further A/A & E/S regarding.**

1. Earlier Diu Airport was operated & maintained by the Diu Administration (U.T.). In March 2017, Diu Airport was handed over to Airports Authority of India.
2. At present, work “Construction of ATC tower cum technical block cum fire station at Diu Airport, Diu” is under progress.
3. Electrical/Electronic equipment may be install in the following areas of ATC tower:-
  - i. Equipment room, Battery backup room, OSCH room, EPABX room, MET officer with instrument, Instrument maintenance store room at Second floor.
  - ii. Fire watch tower at Sixth floor.
  - iii. Air traffic controllers (ATC) room at Seventh floor.
4. As per AAI circular ref. no. EI0060/NM-1500/6/2016-CNS-OM dated 26/06/2016, para (a) states that “*Installation of fire suppression system as per National/ International Standards which are suitable for electronic System for all the new ATC Tower cum ATS Complexes.*”. Hence Fire suppression system is considered for areas mentioned in above para (3).
5. In view of above, an estimate amounting Rs 43,52,222 /- (including Labour cess@1%, GST@18% and contingency@3%) has been prepared and put up for budget allocation and accord of A/A & E/S please.

Submitted please.

03/03/2020 5:38 PM

**RAM ROOP MEENA  
(JE(E-E)-WR)**

**Note No. #2**

Please refer preceding note and enclosed document following points may please be noted:-

1) Please refer page no. 1/53 of attached documents in which ION of Directorate of CNS-OM issued on dated 22/06/2016. It is mentioned in ION that "*Fire suppression system suitable for electronic systems as per national/ international standards should be provided at ATS complex and other CNS/ATM equipment sites. As per BIS:IS- Fire protection of electronic data processing installation and other international standards like NFPA (NFPA 75 & 76) etc. Gas based (Clean Agent/CO2 based) fire suppression system is to be provided for Electronic System.*"

It is also mentioned in Para(a) that "*Installation of Fire Suppression as per the National/ International standards which are suitable for Electronic System for all the New ATC Tower cum ATS Complexes.*"

2) According to above guideline, it is proposed by Jr. Executive (E-E) to provide Fire Suppression system in following areas:-

i. Equipment room, Battery backup room, OSCH room, EPABX room, MET officer

with instrument, Instrument maintenance store room at Second floor.

ii. Fire watch tower at Sixth floor.

iii. Air traffic controllers (ATC) room at Seventh floor.

3) In view of above, Jr. Executive (E-E) has prepared an estimate amounting Rs 43,52,222 /-

(including Labour cess@1%, GST@18% and contingency@3%) has been prepared and

Hence same is put up for budget allocation and accord of A/A & E/S please.

Submitted please.

03/03/2020 6:56 PM

**ANIL KUMAR**  
**(MGR(E-E)-WR)**

**Note No. #3**

1). In reference to page no. 1/53 of attached documents : ION of Directorate of CNS-OM issued on dated 22/06/2016 for "*Fire suppression system suitable for electronic systems as per national/ international standards should be provided at ATS complex and other CNS/ATM equipment sites. As per BIS:IS- Fire protection of electronic data processing installation and other international standards like NFPA (NFPA 75 & 76) etc. Gas based (Clean Agent/CO2 based) fire suppression system is to be provided for Electronic System.*"

**Also mentioned in Para(a) that " Installation of Fire Suppression as per the National/ International standards which are suitable for Electronic System for all the New ATC Tower cum ATS Complexes."**

2). Gas based Fire Suppression system for the following areas are

proposed:-

i. Equipment room, Battery backup room, OSCH room, EPABX room, MET officer with instrument, Instrument maintenance store room at Second floor.

ii. Fire watch tower at Sixth floor and Air traffic controllers (ATC) Tower at Seventh floor.

3). Estimate is prepared amounting to Rs 43,52,222 /- (including Labour cess@1%, GST@18% and contingency@3%) is put up for budget allocation and accord of A/A & E/S please.

4). Estimate is supported by Budgetary offers/rate analysis/relevant document for accord of A/A & E/S please.

5). No specific budget provision is available for this scheme but work is essential for Operational requirement. Budget provision will be made available from Mis. RED fund.

Submitted please

22/04/2020 2:22 PM

**C S SHEWARE**  
(AGM(E-E)-WR)

#### **Note No. #4**

Regarding fund requirement, confirm whether fund from any scheme of the approved capital budget 2020-21 can be taken for this proposed work.

27/04/2020 10:42 AM

**K M NOORJAHAN**  
(JGM(E-E)-WR)

#### **Note No. #5**

1. No specific budget provision is available for this scheme but work is essential for Operational requirement.

2. Budget provision may be made available from Miscellaneous RED fund or RCS fund.

Submitted please

04/05/2020 3:58 PM

**C S SHEWARE**  
(AGM(E-E)-WR)

#### **Note No. #6**

1.The subject file may please be routed through APD, Diu Airport

2. Also confirm who is the competent authority to accord AA&ES for this work.

05/05/2020 10:31 AM

K M NOORJAHAN  
(JGM(E-E)-WR)

### Note No. #7

Please refer preceding note

1. An estimate amounting Rs 43,52,222 /- (including Labour cess@1%, GST@18% and contingency@3%) for the Non-budgeted Scheme work **"Provision of gas based fire suppression system for ATC tower & technical block at Diu Airport."** was prepared by Jr. Executive(E-E).
2. Case file is put up for accord of A/A & E/S please.
3. As per DOP Para 8.1(a), APD is the competent authority for accord of A/A & E/S. (Copy enclosed)

Submitted please.

05/05/2020 3:02 PM

ANIL KUMAR  
(MGR(E-E)-WR)

### Note No. #8

Please refer previous note, file is forwarded for necessary budget allocation and further financial concurrence for accord of A/A & E/S.

05/05/2020 3:13 PM

A A ANSARI  
(APD(DIU)-WR)

### Note No. #9

1. Please refer to note#1 to note#8 on the subject.
2. The current proposal is for Provision of Gas based fire suppression system for New ATC Tower & Technical Block at Diu Airport with an estimated amount of Rs 43,52,222/-(I/c labour cess @1% ,GST @ 18%and contingencies @3%).
3. The proposal forwarded by field engineers for obtaining fund allocation and financial concurrence to accord AA&ES.
4. Approved capital budget is not available for this work.
5. Hence the case is recommended for fund allocation from Misc. RED's fund and financial concurrence for accord of AA&ES.  
Submitted please.

06/05/2020 11:27 AM

K M NOORJAHAN  
(JGM(E-E)-WR)

### Note No. #10

For allocation of fund please.

06/05/2020 12:44 PM

एस के गुप्ता|S K GUPTA  
(महाप्रबंधक (इंजी-सिविल/विद्युत)-प.क्षे.)|GM(E-C)-WR)

### Note No. #11

Fund of Rs. 2 lacs has been allocated in BE 20-21 from RED Misc Fund for the subject work.

Submitted please.

13/05/2020 3:28 PM

R A BHARSAIYA  
(AGM(E-C)-WR)

### Note No. #12

18/05/2020 11:59 AM

एस के गुप्ता|S K GUPTA  
(महाप्रबंधक (इंजी-सिविल/विद्युत)-प.क्षे.)|GM(E-C)-WR)

### Note No. #13

1.With reference to note#11, fund for the subject work has been allocated from RED's Misc fund in BE 20-21.

2.Sufficient amount of this work shall be included in RE 20-21 at the time of projection of Capital Budget RE 20-21.

3.Therefore the case is recommended for accord of financial concurrence to AA&ES for an amount of Rs 43,52,222/-.

Submitted please.

18/05/2020 2:13 PM

K M NOORJAHAN  
(JGM(E-E)-WR)

### Note No. #14

22/05/2020 11:37 AM

एस के गुप्ता|S K GUPTA  
(महाप्रबंधक (इंजी-सिविल/विद्युत)-प.क्षे.)|GM(E-C)-WR)

### Note No. #15

22/05/2020 4:25 PM

जे बालाशेखर|J BALA SEKAR  
(महाप्रबंधक(वित्त)-प.क्षे.)GM(FIN)-WR)

**Note No. #16**

22/05/2020 7:12 PM

SATYAJIT LAI  
(JGM(FIN)-WR)

**Note No. #17**

22/05/2020 8:19 PM

RAMA D PAWAR  
(SM(FIN)-WR)

**Note No. #18**

**कृपया पिछले पृष्ठ पर स्थित टिप्पणीयोंका अवलोकन करें -**

1. The proposal is for accord of AA & ES for the work "Provision of gas based fire suppression system for ATC tower & technical block at Diu Airport." The estimated cost of work is Rs.37,04,784.00 i/c. including 3% contingencies, excluding GST.
2. According to history sheet, As per AAI circular ref. no. EI0060INM-1500/6/20 16-CNS-OM dated 26/0612016. para (a) states that "Installation of fire suppression system as per National/ International Standards which are suitable for electronic System for all the new A TC Tower cum ATS Complexes." And circular ref. no. AAICNS-P III NEW ATS Complex/2019. dated 13/02/2020 states that "as per BIS guidelines. Fire suppression system as per IS 15493 or International standard NFPA 75 should be provided to buildings". Hence Fire suppression system is considered for ATC tower & technical block at Diu Airport.
3. As per Engg. Dept. Budget of Rs 2.00 Lakh is provided from RED Misc Funde BE 2020-21.
4. As per D.O.P. para 8.1(a), APD Diu is the Competent Authority to accord AA & ES.
5. In view of the above we may accord Financial Concurrence for accord of AA & ES for Rs.37,04,784.00 (Rupees Thirty Seven Lakh Four Thousand Seven Hundred and Eighty Four Only) i/c. including 3% Contingency & excluding GST for the work "Provision of gas based fire

suppression system for ATC tower & technical block at Diu Airport.”

अनुमोदन हेतु प्रस्तुत

26/05/2020 11:35 AM

SUDHAKAR YADAV  
(JE(FIN)-WR)

### Note No. #19

*Reference notes ante.*

*In view of above and on recommendation of Jt GM(E-E) WR, the proposal may be financially concurred for Rs.37,04,784/-- (Rupees Thirty seven lakhs four thousand seven hundred eighty four only) Plus GST for accord of AA & ES for work “Provision of Gas based fire suppression system for ATC Tower & Technical block at Diu Airport”, under DOP para 8.1(a) where APD, Diu is the Competent Authority to accord AA&ES, subject to:-*

- i. Engg Deptt may ensure Inclusion of this work in Commitment Budget 2020-21 after receipt of approved Commitment Budget 2020-21 from CHQ.*
- ii. Engg Deptt may ensure sufficient budget provision in Expenditure budget.*
- iii. Considering the current scenario & in lieu of the CHQ circular no. AAI/CHQ/PRE-CHECK/2020-21 dated 10.05.2020, regarding Fund Management due to impact of Covid 19 lock down, Engg Deptt may ensure fund availability before recommending for payment of bill, keeping in view the operational requirement. Submitted please.*

*JT GM(Fin)*

27/05/2020 1:01 PM

RAMA D PAWAR  
(SM(FIN)-WR)

### Note No. #20

concurred as proposed being operational requirement

JtGM(E\_E)

31/05/2020 12:00 AM

SATYAJIT LAI  
(JGM(FIN)-WR)

**Note No. #21**

For further action please.

01/06/2020 12:49 PM

K M NOORJAHAN  
(JGM(E-E)-WR)

**Note No. #22**

As per D.O.P. para 8.1(a), Airport Director, Diu is the Competent Authority to accord AA & ES, as the proposal has been financially concurred for Rs. 37,04,784/- excluding GST by finance section.

Submitted please.

01/06/2020 3:40 PM

C S SHEWARE  
(AGM(E-E)-WR)

**Note No. #23**

Approved. For further necessary action please.

02/06/2020 3:54 PM

A A ANSARI  
(APD(DIU)-WR)

**Note No. #24**

please go through the previous note and put up TS estimate, ENIT, DNIT etc. At the earliest.

04/06/2020 12:52 PM

ANIL KUMAR  
(MGR(E-E)-WR)

**Note No. #25**

1. Please find enclosed DNIT, TS Memo, TS Estimate, AOR, Revised measurement sheet and supporting documents.
2. A/A & E/S amount is Rs. 37.05 lakh plus GST. After inclusion of items for providing fire detection & alarm system in terminal building, amount has been increased in TS Estimate i.e Rs. 39.04 lakh(i/c labour cess & contingency) plus GST.

Submitted for approval and further necessary action please.

30/06/2020 4:16 PM

RAM ROOP MEENA  
(JE(E-E)-WR)

**Note No. #26**

Please refer preceding NOTE,

1. Draft NIT, TS Memo and TS Estimate with supporting documents are prepared by JE(E-E) & enclosed.
2. Difference in A/A & E/S amount and TS Estimate amount is observed due to including the items and quantities in the TS Estimate for providing Fire Detection & Alarm System in Terminal building and offices.
3. This works include (i) Providing Gas based Fire suppression system for upcoming New Technical block, Fire Watch Tower and ATC Tower (ii) Providing Fire Detection & Alarm system for Terminal building and offices, as there is no other facility available except Fire extinguisher in existing Terminal building & offices.
4. This work is very essential to complete in time bound manner for successful operational of upcoming ATC tower cum Technical block cum Fire station and providing additional facility to existing Terminal building for Fire detection & alarm.

Submitted for approval & further necessary action please.

30/06/2020 6:33 PM

ANIL KUMAR  
(MGR(E-E)-WR)

**Note No. #27**

Process the case of TS and further tender action.

02/07/2020 11:41 AM

K M NOORJAHAN  
(JGM(E-E)-WR)

**Note No. #28**

PI Check and correct the D/NIT as discussed for above said work for further Tendering action.

17/07/2020 6:22 PM

C S SHEWARE  
(AGM(E-E)-WR)

**Note No. #29**

Please refer preceding note and do the needful.

20/07/2020 10:53 AM

**ANIL KUMAR**  
(MGR(E-E)-WR)

### Note No. #30

Please find enclosed here corrected DNIT.

Submitted for Approval and further necessary action please.

20/07/2020 1:24 PM

**RAM ROOP MEENA**  
(JE(E-E)-WR)

### Note No. #31

Please refer preceding Note, JE(E-E) corrected the DNIT as advised and submitted for further necessary action. Same is also forwarded in editable format vide email dated 20/07/2020 for any further corrections at your end please.

20/07/2020 5:28 PM

**ANIL KUMAR**  
(MGR(E-E)-WR)

### Note No. #32

| <b>MEMO FORWARDING NOTE E-TENDERING (Tender ID: 2020_AAI_52328_1)</b> |                                                                                                              |                                                                                                                               |
|-----------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------|
| 1                                                                     | Nam Name of work:                                                                                            | PROVISION OF GAS BASED FIRE SUPPRESSION SYSTEM FOR ATC TOWER CUM TECHNICAL BLOCK AT DIU AIRPORT. (Bid No. : 2020_AAI_52328_1) |
| 2                                                                     | Ref. to AA & ES                                                                                              |                                                                                                                               |
| (i)                                                                   | No & Date                                                                                                    | AAI/RHQ-WR/DIU/ENGG (E) /AA & ES-01/2020-21<br>Date:02.06.2020                                                                |
| (ii)                                                                  | Amount                                                                                                       | Rs. 37,04,784.00(Excluding GST @18%)<br><b>(Rs. 43,71,645.00 Including GST @ 18%)</b>                                         |
| 3                                                                     | Ref. to Technical Sanction                                                                                   |                                                                                                                               |
| (i)                                                                   | No & Date                                                                                                    | AAI/MUM/AGM (E-E)/Diu/CAP/TS-01/2020-21/<br>Date:13.07.2020                                                                   |
| (ii)                                                                  | Amount                                                                                                       | Rs. 45,86,516.00 (Including GST @18%)                                                                                         |
| 4                                                                     | Scope of work for which tenders have been called for clearly indicating the item omitted from the sanctioned | PROVISION OF GAS BASED FIRE SUPPRESSION SYSTEM.                                                                               |

|       |                                                                                            |                                                                                 |
|-------|--------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------|
|       | estimate                                                                                   |                                                                                 |
| 5     | Ref. to Approval of NIT                                                                    |                                                                                 |
| (i)   | Authority                                                                                  | Asst. General Manager (Engg-E)                                                  |
| (ii)  | Estimate Amount put to tender                                                              | Rs.37,90,509.00 (Ex. GST)                                                       |
| 6     | Ref. to Publicity                                                                          |                                                                                 |
| (i)   | Date on which Notice Inviting Tender was placed on Notice Board                            | 23.07.2020                                                                      |
| (ii)  | Date on which it was circulated to other offices & AAI website                             | 27.07.2020 & AAI website on 23.07.2020                                          |
| (iii) | Name of Newspaper (with dates) in which the Notice Inviting Tender was actually advertised | NA                                                                              |
| 7     | The date and time at which                                                                 |                                                                                 |
| (i)   | tenders were due to be submitted                                                           | 04.08.2020 Up to 18:00hrs                                                       |
| (ii)  | Postponed date and time if any                                                             | No                                                                              |
| (iii) | Reasons for postponements                                                                  | -                                                                               |
| (iv)  | Reference to Publicity in regards to postponement to tenders                               | -                                                                               |
| 8     | The date from which tenders were available for sale to contractors                         | 24.07.2020                                                                      |
| 9     | <b>Particulars of Contractors submitted the bid;</b>                                       |                                                                                 |
| i)    | M/s. Yash Energy Pvt. Ltd.                                                                 | Bidder                                                                          |
| ii)   | M/s.Industrial project & Products co.                                                      | Bidder                                                                          |
| iii)  | M/s. Fire System.                                                                          | Bidder                                                                          |
| iv)   | M/s. advent electrical technologies pvt. ltd                                               | Bidder                                                                          |
| v)    | M/s. Centre Tap Engineering                                                                | Bidder                                                                          |
| vi)   | M/s. Oasis Engineers                                                                       | Bidder                                                                          |
| vii)  | M/s. Bharati Fire Engineers                                                                | Bidder                                                                          |
| viii) | M/s. Taral Electricals.                                                                    | Bidder                                                                          |
| ix)   | M/s. Lambda Technologies LLP.                                                              | Bidder                                                                          |
| 10    | <b>Opening of Tenders</b>                                                                  |                                                                                 |
| (i)   | Date & time at which tenders were due to be opened                                         | a) Cover I On 10/08/2020 at 11.00 hrs<br>b) Cover II On 14/08/2020 at 11.00 hrs |
|       | Date & time at which tenders were actually opened                                          | a) Cover I On 10/08/2020 at 11.00 hrs<br>b) Cover II On 14/08/2020 at 13.00 hrs |

|       |                                                                                                    |                                                                           |                     |          |
|-------|----------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------|---------------------|----------|
| (iii) | Name & Designation of Officers who actually opened the Tender                                      |                                                                           |                     |          |
|       | Cover I & II                                                                                       | 1. C. S. Sheware, AGM(E-E) Bid Manager 2. Sh. Chandrakant Patade SM (fin) |                     |          |
|       | Cover III                                                                                          | 1. C. S. Sheware, AGM(E-E) Bid Manager 2. Sh. Chandrakant Patade SM (fin) |                     |          |
| (iv)  | Name of contractors present at the time of opening of tender                                       | NO                                                                        |                     |          |
| (vi)  | Name and Designation of any other person present                                                   | NO                                                                        |                     |          |
| (vii) | Have all the contractors deposited EMD                                                             | YES                                                                       |                     |          |
| 11    | Position of tenders received ( Financial Bid)                                                      |                                                                           |                     |          |
|       | Contractors                                                                                        | Tendered Amount (Excl. GST)                                               | % above or below JC | Position |
| i)    | M/s. Yash Energy Pvt. Ltd.                                                                         | Rs. 32,48,692.00                                                          | 14.29% below        | L2       |
| ii)   | M/s.Industrial project & Products co.                                                              | Rs.3520364.00                                                             | 7.12% below         | L6       |
| iii)  | M/s. Lambda Technologies LLP.                                                                      | Rs.3507450.00                                                             | 7.46% below         | L5       |
| iv)   | M/s. advent electrical technologies pvt. ltd                                                       | Rs. 3259800.00                                                            | 14.00% below        | L3       |
| v)    | M/s. Centre Tap Engineering                                                                        | Rs. 3312025.00                                                            | 12.62% below        | L4       |
| vi)   | M/s. Oasis Engineers                                                                               | Rs. 3589900.00                                                            | 5.29% below         | L7       |
| vii)  | M/s. Bharati Fire Engineers                                                                        | Rs. 3234997.54                                                            | 14.65% below        | L1       |
| viii) | M/s. Taral Electricals.                                                                            | Rs. 36387.00                                                              | 4.06% below         | L8       |
| 12    | Justified cost as worked out by AGM E(E)                                                           | Rs 43,71,645.00 (Excluding GST @18%)                                      |                     |          |
| 13    | Date on which validity of tender expires                                                           | 90 days from the date of opening                                          |                     |          |
| (i)   | Availability of site                                                                               | Available                                                                 |                     |          |
| (ii)  | Availability of stipulated material                                                                | To be arranged by contractor                                              |                     |          |
| (iii) | Approval of layout plans                                                                           | N/A                                                                       |                     |          |
| (iv)  | Approval to buildings, Plans, Clearance from local body                                            | N/A                                                                       |                     |          |
| (v)   | Is this first call of tenders? If not, details of previous call and result                         | Yes                                                                       |                     |          |
| (vi)  | Justification                                                                                      | Based on MR.                                                              |                     |          |
| (vii) | Comments on the capabilities of the lowest tenders including their financial & technical resources | Technically & financially capable to carry out the work                   |                     |          |

**Remarks & Recommendations: -**

1. E-Tender was floated for the above said on 23/07/2020 The envelope No I (Fee) with (PQQ) was opened on 10/08/2020.
2. The bid of 09 (nine) nos. agencies who had submitted the hard copies were scrutinized & found that all the 08 (Eight) agencies are eligible. The price bid (Envelope-II) of 08 (eight) eligible bidders are opened online on 14/08/2020 at 13.00 hrs.
3. The comparative statement generated from CPP portal with justification cost as the base are kept in the file.
4. M/s. Bharati Fire Engineers, who had quoted Rs.32,34,997.54 (Rupees Thirty Two lakhs Thirty Four thousand Nine hundred ninety seven & fifty fore paise only) which is **14.65% below** the justified cost of Rs.37,90,509.00 becomes the L-1 Bidder.
5. The Expenditure for this work can be met through RE 2020-21 Capital Budget for the electrical works for Diu Airport Rs. 25.00 lacs is available in the budget.
6. As per DOP para 8.5 (a), Asst.GM(E-E) is the competent authority to accept the bid of L-1 bidder received through open tender for award of work.

Submitted for financial concurrence for an amount of Rs. 32,34,997.54 only please.

25/08/2020 3:58 PM

**C S SHEWARE**  
(AGM(E-E)-WR)

**Note No. #33**

25/08/2020 4:14 PM

**SATYAJIT LAI**  
(JGM(FIN)-WR)

**Note No. #34**

26/08/2020 11:09 AM

**RAMA D PAWAR**  
(SM(FIN)-WR)

**Note No. #35**

कृपया पिछले पृष्ठ पर स्थित टिप्पणीयोंका अवलोकन करें -

It may be confirmed that budget provision for RE 2020-21 is approved or proposed. Budget provision in BE 2020-21 may be placed in the file for FC.

26/08/2020 5:24 PM

SUDHAKAR YADAV  
(JE(FIN)-WR)

**Note No. #36**

1). Budget provision of Rs. 25.00 lacs is proposed in RE 2020-21 and copy is enclosed at page No. 1015 (Sr. No. 07) in the file.

Resubmitted for F/C Please.

27/08/2020 2:14 PM

C S SHEWARE  
(AGM(E-E)-WR)

**Note No. #37**

**कृपया पिछले पृष्ठ पर स्थित टिप्पणीयोंका अवलोकन करें -**

1. The proposal is for seeking Financial Concurrence in favour of L1 bidder M/s Bharati Fire Engineers with quoted amount of Rs.32,34,998/- excluding GST which is 14.66% below the Justified Cost of Rs.37,90,509/- for the work "Provision of gas based fire suppression system for ATC tower & technical block at Diu Airport".
2. The Technical Sanction for the same work is sanctioned by AGM (E-E) WR for Rs.45,86,516 including 3% Contingencies and GST vide Technical Sanction-01/2020 dated 13.07.2020
3. AA & ES for the same work is accorded for Rs.37,04,784.00 by the Competent Authority.
4. As per Engg. Dept. there is budget provision of Rs.25.00 Lakh in Proposed RE 2020-21 for the the same work.
5. As per D.O.P. para 8.5(a), AGM (E-E), WR is the Competent Authority to accept this tender.
6. In view of the above, the proposal may be considered for accord for Financial Concurrence in favour of L1 bidder M/s. Bharati Fire Engineers with quoted amount of Rs.32,34,998/- (Rupees Thirty Two Lakh Thirty Four Thousand Nine Hundred and Ninety Eight Only) excluding GST for the work "Provision of gas based fire suppression system for ATC tower & technical block at Diu Airport".

अनुमोदन हेतु प्रस्तुत

28/08/2020 5:04 PM

SUDHAKAR YADAV  
(JE(FIN)-WR)

**Note No. #38**

*Reference notes ante.*

*In view of above, the proposal is financially concurred in favour of L1 bidder M/s Bharati Fire Engineers for quoted amount of Rs.32,34,998/- (Rupees Thirty two lakhs thirty four thousand nine hundred ninety eight only) plus GST, which is 14.66% below justified cost of Rs.37,90,509/- for work " Provision of gas based fire suppression system for ATC tower & technical block at Diu Airport", under DOP para 8.5(a) where AGM(E-E), WR is the competent authority to accept the proposal, subject to:*

- a. *GST shall be paid against Valid Tax Invoice.*
- b. *Engg Deptt may ensure sufficient provision before incurring expenditure.*
- c. *Engg Deptt may kindly ensure that the expenditure is restricted as per the Reduced R & M Budget circulated vide CHQ letter No. AAI/ED(Fin)-II/4/2020/02 dated 1st July,2020. .*
- d. *Considering the current scenario & lieu of the CHQ circular no. AAI/CHQ/PRE-CHECK/2020-21 dated 10.05.2020, regarding Fund Management due to impact of Covid 19 lock down, Engg may ensure Fund availability before recommending for payment of bill, keeping in view the operational requirement.*

31/08/2020 3:12 PM

RAMA D PAWAR  
(SM(FIN)-WR)

Signature Not Verified

Digitally signed by CHANDRASHEKHAR  
SHIVAJI SHEWARE  
Date: 2021.05.25 14:28:38 IST  
Location: eProcurement System for  
Central PSUs