

TENDER NO.: AAI/CL/CNS/UPS/NIT-14/2020-21 Dated: 25-07-2019

Subject: SITC OF 10KVA/15KVA MODULAR UPS & 3KVA ONLINE UPS FOR CALICUT AIRPORT AND ITS CAMC FOR FIVE YEARS.

.

The technical bid of the tender SITC OF 10KVA/15KVA MODULAR UPS & 3KVA ONLINE UPS FOR CALICUT AIRPORT AND ITS CAMC FOR FIVE YEARS was opened on 26-11-2020. Following bidders participated in the tender.

1. PowerOn micro system, Bangalore
2. Better Power Solutions, Guwahaty.
3. Novateur Electrical & Digital system, Chennai

Tender Evaluation Committee (TEC) consisting of the following officers has evaluated the Technical bids.

1. Shri. Anilkumar K, AGM(CNS)
2. Shri. Mohammed Asif, SM(CNS)
3. Shri. Rahul VK, AM(CNS)

As per Technical evaluation report submitted on 17-12-2020 by TEC, M/s Poweron Micro system, Bangalore and M/s Better power solution, guwahaty does not fulfill all conditions for technical evaluation and hence committee rejected their bids.

1. 10KVA/15KVA MODULAR UPS offered by M/s. Better Power Services Pvt Ltd. does not include multiple control cards for ensuring redundancy as per our requirement (Annexure III Technical Specifications for 10KVA/15KVA Modular UPS Sl.No. A.8).
2. Many of the Technical specifications required for 10KVA/15KVA MODULAR UPS are only partially complied by M/s. Power One Micro Systems Pvt Ltd. (Annexure III Technical Specifications for 10KVA/15KVA Modular UPS).

Hence the committee recommends the bid submitted by M/s. Novateur Electrical & Digital Systems Pvt Ltd. for further processing as per the terms and conditions.

(E.V.ABDUL KAREEM)

AGM (CNS)