


**COMPARATIVE STATEMENT FOR PROCUREMENT OF 10KVA ONLINE UPS (REF-AAI/CNS/TPT/UPS/E-T/2020)**


Tender for "SITC of 10KVA online UPS with 5 years of CAMC after 3 years of standard warranty period" Envelope -1 (Fee) has been opened on 01.12.2020, by the duly constituted committee. Six online bids were received, and all tenders qualified for Technical evaluation. The Comparative statement for Envelope-1 is as below.

**EVALUATION OF ENVELOPE-1: FEE**


| SNO | TENDER PARTY/NUMBER    | FEE<br>EXEMPTION<br>CERTIFICATE | EMD<br>EXEMPTION<br>CERTIFICATE | ANNEXURE<br>IV | ANNEXURE<br>VI | POA/<br>AUTHORISATION<br>LETTER | REMARKS |
|-----|------------------------|---------------------------------|---------------------------------|----------------|----------------|---------------------------------|---------|
| 1   | BETTER POWER/217407    | YES                             | YES                             | YES            | YES            | YES                             |         |
| 2   | PERPETUAL POWER/218903 | YES                             | YES                             | YES            | YES            | YES                             |         |
| 3   | POWER ONE/219197       | YES                             | YES                             | YES            | YES            | YES                             |         |
| 4   | SK TECHNO SOL/219397   | YES                             | YES                             | YES            | YES            | YES                             |         |
| 5   | PROSTRAM INFO/219432   | YES                             | YES                             | YES            | YES            | YES                             |         |
| 6   | INTEGRATED TECH/219665 | YES                             | YES                             | YES            | YES            | YES                             |         |

  
R CHANDRAKANTH  
MGR (FIN)

  
M. MURALIKRISHNA M  
MGR (E-E)

  
OMJE V  
MGR (CNS)

  
DGM (CNS)

  
APD  
03/12/2020

**COMPARATIVE STATEMENT FOR PROCUREMENT\* OF 10KVA ONLINE UPS (REF-AAI/CNS/TPT/UPS/E-T/2020)\***

Tender for "SITC of 10KVA online UPS with 5 years of CAMC after 3 years of standard warranty period" Envelope -2 (PQQ/TECHNICAL) has been opened on 02.12.2020, by the duly constituted committee. The Comparative statement for Envelope-2 is as below.

**EVALUATION OF ENVELOPE-2: PQQ/TECHNICAL**

| SNO | TENDER PARTY/NUMBER    | COPY OF PAN | COPY OF GST | OEM AUTHORIZATION | BALANCE SHEET (3 YRS) | PROFIT & LOSS STMT (3 YRS) | PERFORMANCE CERTIFICATE/ PROOF OF EXPERIENCE | LIST OF DELIVERABLES | COPY OF NOT BLACK LISTED | AMC (5 YRS) | COMPLIANCE STATEMENT OF SECTION-I, II, III | REMARKS |
|-----|------------------------|-------------|-------------|-------------------|-----------------------|----------------------------|----------------------------------------------|----------------------|--------------------------|-------------|--------------------------------------------|---------|
| 1   | BETTER POWER/217407    | YES         | YES         | YES               | NO                    | NO                         | PARTIAL                                      | NO                   | YES                      | YES         | YES                                        |         |
| 2   | PERPETUAL POWER/218903 | YES         | YES         | YES               | YES                   | YES                        | YES                                          | YES                  | YES                      | YES         | PARTIAL                                    |         |
| 3   | POWER ONE/219197       | YES         | YES         | YES               | YES                   | YES                        | YES                                          | PARTIAL              | YES                      | YES         | YES                                        |         |
| 4   | SK TECHNO SOL/219397   | YES         | YES         | YES               | YES                   | YES                        | NO                                           | NO                   | YES                      | NO          | NO                                         |         |
| 5   | PROSTRAM INFO/219432   | YES         | YES         | YES               | YES                   | YES                        | YES                                          | NO                   | YES                      | NO          | NO                                         |         |
| 6   | INTEGRATED TECH/219665 | YES         | YES         | YES               | YES                   | YES                        | NO                                           | YES                  | YES                      | NO          | NO                                         |         |


The following shortcomings are noted in the tenders:

1. BETTER POWER/217407: (i) PERFORMANCE & WORK COMPLETION CERTIFICATE NOT AVBL  
(ii) IN DETAILS OF BALANCE SHEET & PROFIT LOSS FOR 3 YRS  
(iii) LIST OF DELIVERABLE ITEMS (MAKE & MODEL OF UPS AND BATTERIES) NOT MENTIONED
2. PERPETUAL POWER/218903: (i) NOT MENTIONED COMPLIED/NOT COMPLIED STATEMENT IN SECTION II of 12.2


3. POWER ONE/219197: (i) LIST OF BATTERY DETAILS NOT MENTIONED IN DELIVERABLE ITEMS
4. SK TECHNO SOL/219397: (i) SECTION I, II, III NOT CLEAR  
(ii) AS PER TECHNIACL REQUIREMENTS, BIDDER MENTIONED EXTERNAL ISOLATION TRANSFORMER INSTEAD OF INBUILT ISOLATION TRANSFORMER, HENCE NOT QUALIFIED FOR FINANCIAL BID OPENING  
(iii) PERFORMANCE & WORK COMPLETION CERTIFICATE NOT AVBL
5. PROSTRAM INFO/219432: (i) LIST OF BATTERY DETAILS NOT MENTIONED IN DELIVERABLE ITEMS  
(ii) NOT MENTIONED COMPLIED/NOT COMPLIED STATEMENT IN SECTION II 12.2 & 16  
(iii) IN SECTION I (H-1), BIDDER'S DOESN'T HAVE UPS PASS CERTIFICATION (UPS IS CURRENTLY UNDER TESTING. TEST CERTIFICATE WILL BE PROVIDED AT A LATER DATE). HENCE NOT QUALIFIED FOR FINANCIAL BID OPENING
6. INTEGRATED TECH/219665: (i) WORK COMPLETION CERTIFICATES NOT AVBL & WORK ORDER NOT RELATED TO UPS  
(ii) AS PER TECHNIACL REQUIREMENTS, BIDDER MENTIONED EXTERNAL ISOLATION TRANSFORMER INSTEAD OF INBUILT ISOLATION TRANSFORMER, HENCE NOT QUALIFIED FOR FINANCIAL BID OPENING  
(iii) BIDDER NOT ACCEPTED 5 YEARS CAMC AFTER 3 YRS OF STANDARD WARRANTY (SEC-II,16), HENCE NOT QUALIFIED FOR FINANCIAL BID OPENING


Based on the above short comings, and Bidders **SL.NO 4,5 & 6** not qualified for Financial bid opening due to deviation in technical requirements as per tender. It is proposed to call for shortfall documents through CPP portal to ensure fair competition for remaining bidders (i.e. **SL.NO 1,2 &3**).

  
P CHANDRAKANTH  
MGR (FIN)

  
DGM/(CNS)

APD

  
03/12/2020

  
M. MURALIKRISHNA M  
MGR (E-E)

  
OMJE V  
MGR (CNS)