



AIRPORTS AUTHORITY OF INDIA
ENGINEERING CIVIL WING
BEGUMPET AIRPORT:HYDERABAD



Ref: AAI/HYD/ENGG(c)/RWH/Corrig-01/2024-2025

Dated: 03.06.2024

CORRIGENDUM-01

Tender Reference no : AAI/HYD/ENGG(c)/RWH/2024-2025

Tender ID : 2024_AAI_191987_1

Name of Work : Construction of Rainwater Harvesting System at Begumpet Airport, Hyderabad.

Reference to the tender for the above mentioned work published in CPP portal on 21.05.2024.

The following amendments may be noted.

S.No	Reference	Existing Condition	Amended Condition
1	Item description o Item S.No -19 in BOQ, i.e Polymer Modular Block	Market item: MR-03 – supply & installation of polymer block having size of 800*700*663mm or 683*410*450mm. Volume per storage tank varies from 126 liters to 422 liters. Diameter for connection with pipes 110,125,160,200,250mm having installation depth up to 4mts. Load bearing should at least 30 tons per sqm & lateral load up to 14 tons per sq. approved manufactures of blocks should be Aco, Frankische, Retas Enviro Solutions, Rehau, polypipe	The similar products of polymer blocks of different sizes also will be considered after meeting the technical parameters/ specification as mentioned in the NIT conditions.

All other terms and conditions of the original tender notice remain un altered. This corrigendum shall be form part of the Tender Document/ Agreement

JGM(Engg-Civil)

AAI, Begumpet Airport, Hyderabad